

# PLUMBING

<b>Water Service</b>	Shut off location: Outside at curbside		
Water entry piping:	<input checked="" type="checkbox"/> Not visible	<input type="checkbox"/> Copper/Galv.	<input type="checkbox"/> Plastic/PB <input type="checkbox"/> Unknown
Water lines:	<input checked="" type="checkbox"/> Copper	<input type="checkbox"/> Galvanized	<input type="checkbox"/> Plastic <input type="checkbox"/> <b>Polybutylene</b> <input type="checkbox"/> Unknown
	Lead ( <i>other than solder joints</i> ):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Service entry <input type="checkbox"/> Unknown
	Water flow:	<input checked="" type="checkbox"/> Satisfactory	<input type="checkbox"/> Poor
	Water pressure:	<input checked="" type="checkbox"/> Satisfactory	<input type="checkbox"/> Poor
	Pipes:	<input type="checkbox"/> Corroded <input type="checkbox"/> Leaking	<input type="checkbox"/> Valves broken/missing <input type="checkbox"/> Dissimilar metal
Drain/waste/vent pipe:	<input type="checkbox"/> Copper	<input checked="" type="checkbox"/> Cast iron	<input type="checkbox"/> Plastic <input type="checkbox"/> Other
	Condition:	<input checked="" type="checkbox"/> Satisfactory	<input type="checkbox"/> Marginal <input type="checkbox"/> Poor <input type="checkbox"/> Not visible
	Waste discharge:	<input type="checkbox"/> Satisfactory	<input type="checkbox"/> Slow drain
<b>Gas Lines</b>	<input type="checkbox"/> Not visible	<input type="checkbox"/> Shutoff missing	
	<input type="checkbox"/> Copper	<input type="checkbox"/> Brass	<input checked="" type="checkbox"/> Black iron <input type="checkbox"/> Stainless steel <input type="checkbox"/> CSST
<b>Well Pump</b>	<input checked="" type="checkbox"/> N/A	<b>(See Remarks page)</b>	
	<input type="checkbox"/> Submersible	<input type="checkbox"/> In basement	<input type="checkbox"/> Well house <input type="checkbox"/> Well pit <input type="checkbox"/> Shared well
Pressure gauge operates:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Unknown
<b>Sanitary Pump</b>	<input checked="" type="checkbox"/> N/A		
Sealed crock:	<input type="checkbox"/> Yes <input type="checkbox"/> No	Check valve:	<input type="checkbox"/> Yes <input type="checkbox"/> No
		Vented:	<input type="checkbox"/> Yes <input type="checkbox"/> No
<b>Water Heater #1</b>			
<i>Brand name:</i> Whirlpool	<i>Model #:</i> FG1F40433NOV	<i>Serial #:</i> 0518103722	
	<input checked="" type="checkbox"/> Gas <input type="checkbox"/> Electric	<input type="checkbox"/> Oil <input type="checkbox"/> Other	Approx. age: new yr(s)
Capacity: 40 gallons	Seismic restraints needed: <input checked="" type="checkbox"/> N/A <input type="checkbox"/> Yes <input type="checkbox"/> No		
Relief valve:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<b>Extension proper:</b> <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Missing
Vent pipe:	<input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Satisfactory	<input type="checkbox"/> Improper pitch <input type="checkbox"/> Rusted <input type="checkbox"/> <b>Safety Hazard</b>
<b>Water Heater #2</b>	<input checked="" type="checkbox"/> N/A		
<b>Water Softener</b>	<b>(Unit not evaluated)</b>		
	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Plumbing hooked up: <input type="checkbox"/> Yes <input type="checkbox"/> No	
<b>General Comments</b>			

Temperature-Pressure relief valve extension needs to be 4"-6" off of the floor - this is a Safety Concern.